

Kitemark™ Certificate

This is to certify that:

Zeta Alarm Systems by GLT Exports Ltd
72-78 Morfa Road
Swansea
SA1 2EN
United Kingdom

Holds Certificate Number:


KM 575040

In respect of:

**BS EN 54-2 & BS EN 54-4
Fire Panel & Power Supplies**

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.



For and on behalf of BSI:

Gary Fenton, Global Product Certification Director

First Issued: 08/10/2012

Latest Issue: 19/08/2016



Kitemark™ Certificate

No. KM 575040

BS EN 54-2:1997 + A1 & AC and BS EN 54-4:1998 + A1 & A2

Model Reference	Type
IN1	Infinity 1 Zone Conventional Control and Indicating Equipment.
IN2	Infinity 2 Zone Conventional Control and Indicating Equipment.
IN4	Infinity 4 Zone Conventional Control and Indicating Equipment.
IN6	Infinity 6 Zone Conventional Control and Indicating Equipment.
IN8	Infinity 8 Zone Conventional Control and Indicating Equipment.

Certified for use with Zeta Alarm Systems conventional fire detection and alarm devices.

Options with requirements

Certified with the following options with requirements from BS EN 54-2:1997:

Output to fire alarm devices (clause 7.8)

Delays to outputs (clause 7.11)

Test condition (clause 10)

First Issued: 08/10/2012

Latest Issue: 19/08/2016

Page: 2 of 3

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

Kitemark™ Certificate

No. KM 575040

BS EN 54-2:1997 + A1 & AC and BS EN 54-4:1998 + A1 & A2

Model Reference	Type
ID2/2	Infinity ID2, 2 Zone Addressable Control and Indicating Equipment.
ID2/4	Infinity ID2, 4 Zone Addressable Control and Indicating Equipment.
ID2/8	Infinity ID2, 8 Zone Addressable Control and Indicating Equipment.

Certified for use with Zeta Alarm Systems addressable fire detection and alarm devices.

Options with requirements

Certified with the following options with requirements from BS EN 54-2:1997:

- Output to fire alarm devices (clause 7.8)
- Dependencies on more than one alarm signal (clause 7.12)
- Fault signals from points (clause 8.3)
- Disabling of addressable points (clause 9.5)
- Test condition (clause 10)

First Issued: 08/10/2012

Latest Issue: 19/08/2016

Page: 3 of 3

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.